Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 02/26. Dated: 12/11/2026.

It is certified that an inspection team headed by Dr. Vibha. V

(Name of Officers with designation) from Superintendent of TH Perambra (ic) PHED

inspected the St. Meera's Public School Perambra Kallode

(Name & Address of the school) on 06/11/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. KWA/KKD/PMY/07042/26 dated 07/11/26

of KWA (PHED Lab) certified that the St. Meera's Public School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 05-11-2027

TALUK HOSPITAL ★ PERAMBRA P.O. KOZHIKODE - 673 525 ★ Date: 12/11/26

Signature with Seal: Dr. Vibha V Assistant S...

Name : Dr. Vibha V Reg. No: 282...

Designation : Assistant Surgeon

Name & Address of the Office / Department : .....

the Headmistress

St. Meera's Public School · Perambra

(Name & Address of the Institution)

സുപ്രണ്ട്
താലൂക്ക് ആശുപത്രി
പേരാമ്പ്ര-673525

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal
St. Meera's Public School
Perambra

Scanned with OKEN Scanner

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
KUTTIADY
KOZHIKODE
NABL RECOGNISED DRINKING WATER TESTING LABORATORY
E-mail: waterqualityktdy@gmail.com

TEST REPORT

Report No - KWA/KKD/KTDY/3913/2026 *Date of Report: 03/11/2026*

Customer Name & Address		
MOLYKKUTTY ABRAHAM *9048239757*	*1.Sample received on*	*: 31/10/2026*
	2.Sample Condition	*: FIT FOR ANALYSIS*
	3.Sampling done by	*: PARTY*
	4.Sample Ref. No:	*: NIL*
	5.Sample code	*:3913/2026*
	6.Source of sample	*: BORE WELL WATER*
	7.Sample quantity	*: 1LTR*
	8.Test performing dates	From : 31/10/2026 To: 03/11/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	*Result*
1	Colour	HU	IS 3025 (part 4)-2021 (PLATINUM COBALT VISUAL COMPARISON METHOD)	< 5.0	ND
2	Odour		IS 3025 (part 5)-2018	Agreeable	ND
3	Turbidity	(NTU)	IS 3025 (part 10)-1984 (NEPHLOMETRIC METHOD)	1	3.62
4	pH at 25 °C		IS 3025 (PART 11)-2022	6.5 to 8.5	6.61
5	Alkalinity (as $CaCo_3$)	(mg/litre)	IS 3025 (PART 23)-1986 (INDICATOR METHOD)	200	<5.0
6	Total Dissolved Solids at 180°C (TDS)	(mg/litre)	IS 3025 (part 16)-2023 (GRAVIMETRIC METHOD)	500	49.0
7	Total Hardness (as $CaCo_3$)	(mg/litre)	IS 3025 (part 21)-2009 (EDTA METHOD)	200	30.0
8	Calcium (as Ca)	(mg/litre)	IS 3025 (part 40)-1991 (EDTA METHOD)	75	5.61
9	Magnesium (as Mg)	(mg/litre)	IS 3025 (part 46)-1994 (TITRATION METHOD)	30	<5.0
10.	Chloride (as Cl)	(mg/litre)	IS 3025 (part 32)-1988 (ARGENTOMETRIC METHOD)	250	<5.0

Remarks:- The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed By: Chemist

Authorized By : Ershad O.C

End of Report

Principal
St. Meera's Public School
Perambra

Scanned with OKEN Scanner

KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB
KUTTIADY, KOZHIKODE

E-mail: waterqualitykdy@gmail.com

TEST REPORT

Report No - KWA/KKD/KTDY/3913/2026 Date of Report: 03/11/2025

Customer Name & Address		
MOLYKKUTTY ABRAHAM 9048239757	1.Sample received on	: 31/10/2026
	2.Sample Condition	: FIT FOR ANALYSIS
	3.Sampling done by	: PARTY
	4.Sample Ref. No:	: NIL
	5.Sample code	: 3913/2025
	6.Source of sample	: BORE WELL WATER
	7.Sample quantity	: 1LTR
	8.Test performing dates	From : 31/10/2026 To: 03/11/2026

SL No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14)-2013 (Reaffirmed 2019)		75.96
2	Acidity	(mg/litre)	IS 3025 (part 22)-1986 (Reaffirmed 2019)	3	-
3	Sulphate (as SO_4)	(mg/litre)	IS 3025 (PART 24)-1986 (Reaffirmed 2019)	200	0.1
4	Phosphate [as PO4]	(mg/litre)	IS 3025 (PART 31)-2006 (Reaffirmed 2019)		ABSENT
5	Fluoride (as F)	(mg/litre)	APHA 4500F-D 23rd Edition	1.0	BDL
6	Iron (as Fe)	(mg/litre)	IS 3025 (part 53)-2003 (Reaffirmed 2014)	1.0	0.8
7	Nitrate (as NO_3)	(mg/litre)	APHA4500NO3-B 23rd Edition	45	5.0
8	Ammonia	(mg/litre)	IS 3025 (part 34)-2008 (Reaffirmed 2019)	0.5	0.1
9	Residual Chlorine	(mg/litre)	IS 3025 (part 26)-1986 (Reaffirmed 2019)	0.2	ND

*ND→ Not Detected *BDL→ Below Detectable Limit

Remarks:- *The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed By: Chemist

Authorized By :

End of Report

St. Mary's Public School
Perambra

Scanned with OKEN Scanner

KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB
KUTTIADY, KOZHIKODE
E-mail: waterqualityktdy@gmail.com

Report No - KWA/KKD/KTDY/3913/2026 *Date of Report: 03/11/2026*

Customer Name & Address	*1.Sample received on*	*: 31/10/2026*
MOLYKKUTTY ABRAHAM 9048239757	*2.Sample Condition*	*: FIT FOR ANALYSIS*
	3.Sampling done by	*: PARTY*
	4.Sample Ref. No:	*: NIL*
	5.Sample code	*: 3913/2026*
	6.Source of sample	*: BORE WELL WATER*
	7.Sample quantity	*: 100 ML*
	8.Test performing dates	From : 31/10/2026 To: 03/11/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	*Result*
1	Coliforms	CFU/100ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable in any 100ml sample	NIL
2	E coli	CFU/100ml	IS 15185(part1) 2002 reaffirmed2016	Shall not be detectable In any 100ml sample	NIL

*TNTC → Too Numerous To Count (COLIFORM COUNT ABOVE 300CFU/100 ml)

Remarks:- *The results reported relate only to the sample received and tested. This test Report shall not be reproduced except in full without the written approval of the Laboratory.*

Authorized By :

Principal
St. Meera's Public School
Perambra

Scanned with OKEN Scanner